


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Jun-23	425,000	413,801	210,347	203,454
Jul-23	390,000	267,109	135,436	131,673
Aug-23	399,000	366,119	185,571	180,548
Sep-23	337,000	243,413	123,119	120,294
Oct-23	637,000	624,439	317,183	307,256
Nov-23	834,000	857,725	431,836	425,889
Dec-23	1,015,000	658,931	330,556	328,375
Jan-24	875,000	630,572	316,894	313,678
Feb-24	917,000	0	0	0
Mar-24	802,000	0	0	0
Apr-24	951,000	231,529	116,676	114,853
May-24	601,000	464,507	229,425	235,082
Jun-24	425,000	469,571	236,472	233,099
Production 2024 (ytd) (kWh)	3,696,000	1,796,179	899,467	896,712
Total Production (LTM) (kWh)	8,183,000	4,813,915	2,423,168	2,390,747
Capacity Factor (LTM)	18.27%			

B. Site Energy Production Graph

June-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
July-2024	8.5 Year Preventive Maintenance	~8	W1
July-2024	8.5 Year Preventive Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
W1	7.74	2251.03
W2	4.21	2195.88
Total	11.95	4446.91

G. Billed Data

Meter Reading (Date/Time)	6/29/2024 12:00 AM
Meter To Date Produced	62,566,802 kWh
Meter To Date Consumed	147,172 kWh
Last Reading Produced	62,139,378 kWh
Last Reading Consumed	145,666 kWh
Billed kWh	425,918 kWh
Next Meter Reading	7/29/2024 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project had no energy production February 2024 - March 2024.