


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Jun-23	222,000	225,368
Jul-23	201,000	150,520
Aug-23	211,000	198,475
Sep-23	182,000	133,001
Oct-23	341,000	341,609
Nov-23	445,000	445,528
Dec-23	537,000	378,225
Jan-24	455,000	329,993
Feb-24	478,000	0 ²
Mar-24	422,000	0 ²
Apr-24	499,000	113,878
May-24	318,000	259,723
Jun-24	222,000	260,126
Production 2024 (ytd) (kWh)	2,394,000	963,720
Total Production (LTM) (kWh)	4,311,000	2,611,078
Capacity Factor (LTM)	19.82%	

B. Site Energy Production Graph

June-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
July-2024	6 Year Preventive Maintenance	~15	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
W1		2205.42

G. Billed Data

Meter Reading (Date/Time)	7/1/2024 12:00 AM
Meter To Date Produced	24,322,199 kWh
Meter To Date Consumed	121,366 kWh
Last Reading Produced	24,066,554 kWh
Last Reading Consumed	119,964 kWh
Billed kWh	254,243 kWh
Next Meter Reading	8/1/2024 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project had no energy production February 2024 - March 2024.