


## A. Site Energy Production Summary

		Energy Production (kWh)				
		Site		By Turbine		
		P50 (Expected Prodution)	Actual Production	WG1	WG2	WG3
	Jun-23	714,000	586,809	200,667	193,800	192,342
	Jul-23	566,000	447,128	154,258	148,599	144,271
	Aug-23	514,000	508,391	179,206	161,643	167,542
	Sep-23	716,000	353,349	120,898	111,723	120,728
	Oct-23	1,051,000	833,613	294,717	274,789	264,107
	Nov-23	1,224,000	1,145,351	403,047	369,056	373,248
	Dec-23	1,217,000	968,195	337,648	315,435	315,112
	Jan-24	1,343,000	834,692	299,854	288,942	245,896
	Feb-24	1,133,000	0	0	0	0
	Mar-24	1,312,000	0	0	0	0
	Apr-24	1,272,000	165,611	81,100	0	84,511
	May-24	974,000	443,966	224,384	0	219,582
	Jun-24	714,000	457,519	234,750	0	222,769
Production 2024 (ytd) (kWh)		6,748,000	1,901,788	840,088	288,942	772,758
Total Production	otal Production (LTM) (kWh)		6,157,815	2,329,862	1,670,187	2,157,766
Capacity Factor (LTM)		15.5	58%			

## **B. Site Energy Production Graph**

Total Productio



# **Monthly Report** June-2024



## C. Safety Summary

	This Month	Project Cumulative	
Recordable Incident(s)	0	0	
First Aid	0	0	

#### **D. Planned Maintenance Events**

		Duration	
2	Event	(hr)	Turbine
-2024	5.5 Year Preventive Maintenance	~8	WG 1
-2024	5.5 Year Preventive Maintenance	~8	WG 2
-2024	5.5 Year Preventive Maintenance	~8	WG3
		~	

## **E. Actual Maintenance Events**

		Planned/	Duration	
Date	Event	Unplanned	(hrs)	Turbine
6/1/2024-6/30/2024	Fleet Retrofit Pending	Unplanned	720.00	WG 2 <sup>4</sup>

#### F. Turbine Downtime<sup>1</sup>

Downtime (hr)	This Month	Year To Date	
WG1	1.89	2273.70	
WG2	720.00	3851.94	
WG3	0.96	2331.62	
Total	722.85	8457.26	

# G. Billed Data

Meter Reading (Date/Time)	6/29/2024 12:00 AM
Meter To Date Produced	57,638,806 kWh
Meter To Date Consumed	246,823 kWh
Last Reading Produced	57,211,748 kWh
Last Reading Consumed	244,289 kWh
Billed kWh	424,524 kWh
Next Meter Reading	7/29/2024 12:00 AM

## H. Report Notes and Comments

<sup>&</sup>lt;sup>1</sup> Turbine Availability/Downtime Pending.

<sup>&</sup>lt;sup>2</sup> As a result of previously disclosed circumstances, the project had no energy production February 2024 - March 2024.

<sup>&</sup>lt;sup>3</sup> As a result of previously disclosed circumstances, WG 2 has had no energy production since 01/22/2024.

<sup>&</sup>lt;sup>4</sup> Investigation has transitioned to a Retrofit operation