


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z4	Z5	Z6
Aug-23	448,000	542,148	181,375	178,264	182,509
Sep-23	617,000	359,251	114,733	121,644	122,874
Oct-23	956,000	879,647	289,457	284,843	305,347
Nov-23	1,107,000	1,168,998	394,642	378,664	395,692
Dec-23	1,098,000	967,377	303,513	327,543	336,321
Jan-24	1,251,000	922,137	311,959	310,072	300,106
Feb-24	1,044,000	0	0	0	0
Mar-24	1,119,000	0	0	0	0
Apr-24	1,116,000	0	0	0	0
May-24	876,000	0	0	0	0
Jun-24	637,000	26,101	26,101	0	0
Jul-24	518,000	179,993	142,016	37,977	0
Aug-24	448,000	292,342	145,491	146,851	0
Production 2023 (ytd) (kWh)	7,009,000	1,420,573	625,567	494,900	300,106
Total Production (LTM) (kWh)	10,787,000	4,795,846	1,727,912	1,607,594	1,460,340
Capacity Factor (LTM)	12.13%				

B. Site Energy Production Graph

August-2024



Monthly Report
August-2024

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2024	3.5 Year Preventive Maintenance	~8	Z4
September-2024	3.5 Year Preventive Maintenance	~8	Z5
September-2024	3.5 Year Preventive Maintenance	~8	Z6

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/1/2024-8/31/2024	Turbine Fault	Unplanned	744	Z6
8/6/2024	Weather Shutdown	Unplanned	4.08	Z4, Z5
8/21/2024	Customer Shutdown	Unplanned	7.07	Z5
8/30/2024	3.5 Year Preventive Maintenance	Planned	2.43	Z4
8/30/2024	3.5 Year Preventive Maintenance	Planned	4.83	Z5

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
Z4	7.77	3805.10
Z5	19.49	4413.60
Z6	744	5377.12
Total	771.26	13595.82

G. Billed Data

Meter Reading (Date/Time)	8/17/2024 12:00 AM
Ball 2.0 Production (This Period)	232,260 kWh
Ball 2.0 Consumption (This Period)	2,911 kWh
Billed kWh	229,349 kWh
Next Meter Reading	9/18/2024 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project's energy production was limited beginning 01/22/2024. Z4 resumed operation on 6/28/2024 and Z5 resumed operation on 7/23//2024.

³ Z6 Repair Pending