


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Aug-23	399,000	366,119	185,571	180,548
Sep-23	337,000	243,413	123,119	120,294
Oct-23	637,000	624,439	317,183	307,256
Nov-23	834,000	857,725	431,836	425,889
Dec-23	1,015,000	658,931	330,556	328,375
Jan-24	875,000	630,572	316,894	313,678
Feb-24	917,000	0	0	0
Mar-24	802,000	0	0	0
Apr-24	951,000	231,529	116,676	114,853
May-24	601,000	464,507	229,425	235,082
Jun-24	425,000	469,571	236,472	233,099
Jul-24	390,000	301,440	152,091	149,349
Aug-24	399,000	280,180	140,866	139,314
Production 2024 (ytd) (kWh)	2,766,000	2,377,799	1,192,424	1,185,375
Total Production (LTM) (kWh)	8,183,000	4,762,307	2,395,118	2,367,189
Capacity Factor (LTM)	18.07%			

B. Site Energy Production Graph



Monthly Report

August-2024

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
February-2025	9 Year Preventive Maintenance	~15	W1
February-2025	9 Year Preventive Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/6/2024	Weather Shutdown	Unplanned	4.11	W1
8/6/2024	Weather Shutdown	Unplanned	4.13	W2
8/20/2024	8.5 Year Preventive Maintenance	Planned	5.2	W1
8/21/2024	8.5 Year Preventive Maintenance	Planned	0.71	W1
8/21/2024	8.5 Year Preventive Maintenance	Planned	3.93	W2
8/26/2024	8.5 Year Preventive Maintenance	Planned	1.83	W1
8/26/2024	8.5 Year Preventive Maintenance	Planned	8.06	W2
8/27/2024	8.5 Year Preventive Maintenance	Planned	6.2	W1
8/27/2024	8.5 Year Preventive Maintenance	Planned	7.65	W2
8/28/2024	8.5 Year Preventive Maintenance	Planned	0.35	W1
8/28/2024	8.5 Year Preventive Maintenance	Planned	0.49	W2
8/29/2024	8.5 Year Preventive Maintenance	Planned	0.84	W1

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
W1	21.42	2272.88
W2	25.37	2221.25
Total	46.79	4494.13

G. Billed Data

Meter Reading (Date/Time)	8/29/2024 12:00 AM
Meter To Date Produced	63,172,177 kWh
Meter To Date Consumed	151,055 kWh
Last Reading Produced	62,878,395 kWh
Last Reading Consumed	149,332 kWh
Billed kWh	292,059 kWh
Next Meter Reading	9/29/2024 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project had no energy production February 2024 - March 2024.