


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Aug-23	303,000	352,751	170,780	181,971
Sep-23	431,000	226,645	110,485	116,160
Oct-23	674,000	582,309	277,729	304,580
Nov-23	796,000	809,264	396,263	413,001
Dec-23	820,000	637,044	312,365	324,679
Jan-24	931,000	604,549	291,738	312,811
Feb-24	737,000	0	0	0
Mar-24	777,000	0	0	0
Apr-24	722,000	0	0	0
May-24	564,000	0	0	0
Jun-24	422,000	26,106	0	26,106
Jul-24	351,000	270,166	124,029	146,137
Aug-24	303,000	261,120	136,201	124,919
Production 2024 (ytd) (kWh)	4,807,000	1,161,941	551,968	609,973
Total Production (LTM) (kWh)	7,528,000	3,417,203	1,648,810	1,768,393
Capacity Factor (LTM)	12.97%			

B. Site Energy Production Graph

August-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2024	5.5 Year Maintenance	~8	V1
September-2024	5.5 Year Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/6/2024	Weather Shutdown	Unplanned	6.29	V1, V2
8/10/2024	Turbine Fault	Unplanned	7.29	V2

F. Downtime¹

Downtime (hr)	This Month	Year To Date
V1	7.59	3908.55
V2	18.52	3819.02
Total	26.11	7727.57

G. Billed Data

Meter Reading (Date/Time)	9/1/2024 12:00 AM
Meter To Date Produced	39,200,687 kWh
Meter To Date Consumed	116,308 kWh
Last Reading Produced	38,949,379 kWh
Last Reading Consumed	113,056 kWh
Billed kWh	248,056 kWh
Next Meter Reading	10/1/2024 12:00 AM

H. Report Notes and Comments

¹Turbine Availability/Downtime Pending.

²As a result of previously disclosed circumstances, the project had no energy production February 2024 - May 2024.

³As a result of previously disclosed circumstances, V1 had no energy production February 2024 - June 2024.