

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG 1	WTG 2	WTG 3
Jan-24	1,290,968	1,381,482	471,543	462,558	447,381
Feb-24	1,170,349	1,107,267	415,523	340,449	351,295
Mar-24	1,227,217	1,574,190	537,888	515,417	520,885
Apr-24	1,438,497	1,440,355	491,796	461,645	486,914
May-24	980,450	836,173	284,799	275,439	275,935
Jun-24	649,158	897,472	318,609	299,454	279,409
Jul-24	618,687	494,646	168,488	159,103	167,055
Aug-24	559,508	495,719	172,033	156,575	167,111
Sep-24	603,085	666,318	219,662	225,740	220,916
Oct-24	967,926	968,509	327,746	315,257	325,506
Nov-24	1,362,692	1,392,792	449,512	465,936	477,344
Dec-24	1,254,397	1,505,421	506,487	488,779	510,155
Jan-25	1,290,968	1,781,496	600,395	573,604	607,497
Production 2025 (ytd) (kWh)	1,290,968	1,781,496	600,395	573,604	607,497
Total Production (LTM) (kWh)	12,122,935	13,160,358	4,492,938	4,277,398	4,390,022
Capacity Factor (LTM)	33.29%				

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events


Date	Event	Duration (hr)	Turbine
April-2025	12.5 Year Maintenance	~8	WTG 1
April-2025	12.5 Year Maintenance	~8	WTG 2
April-2025	12.5 Year Maintenance	~8	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/ Unplanned	Duration (hrs)	Turbine
------	-------	-----------------------	-------------------	---------

B. Site Energy Production Graph

January-2025



F. Turbine Downtime ¹

Downtime (hr)	This Month	Year To Date
WTG 1	4.40	4.40
WTG 2	1.80	1.80
WTG 3	1.81	1.81
Total	8.01	8.01

G. Wind Speed & Capacity Factor ²

Wind Speed (mph)	This Month	2024 Annual
WTG 1	4.94	4.94
WTG 2	4.90	4.90
WTG 3	4.97	4.97
Estimated	15.49	13.39

Capacity Factor (%)	This Month	2024 Annual
WTG 1	53.80%	42.25%
WTG 2	51.40%	41.45%
WTG 3	54.44%	40.09%
Low Estimate	34.17%	28.72%

H. Report Notes and Comments

¹ Turbine Downtime/Availability Pending

²Wind Speed Pending