



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Jan-24	460,000	266,509
Feb-24	372,000	77
Mar-24	417,000	0
Apr-24	399,000	71,938
May-24	311,000	176,362
Jun-24	228,000	182,891
Jul-24	179,000	130,160
Aug-24	157,000	115,765
Sep-24	224,000	147,046
Oct-24	338,000	226,873
Nov-24	402,000	312,105
Dec-24	403,000	344,484
Jan-25	460,000	442,965
Production 2025 (ytd) (kWh)	460,000	442,965
Total Production (LTM) (kWh)	3,890,000	2,150,666
Capacity Factor (LTM)	16.32%	

B. Site Energy Production Graph

January-2025



Monthly Report

January-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2025	8.5 Year Preventive Maintenance	~8	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
1/28/2025-1/29/2025	Grid Fault	Unplanned	30.61	H1

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
H1	35.41	35.41

G. Billed Data

Meter Reading (Date/Time)	1/28/2025 12:00 AM
Meter To Date Produced	28,017,883 kWh
Meter To Date Consumed	108,044 kWh
Last Reading Produced	27,580,325 kWh
Last Reading Consumed	107,702 kWh
Billed kWh	437,216 kWh
Next Meter Reading	2/26/2025 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project had no energy production February 2024-March 2024 other than 77kWh for testing.