


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Feb-24	1,213,000	0	0	0	0
Mar-24	1,339,000	0	0	0	0
Apr-24	1,327,000	57	0	0	57
May-24	1,052,000	0	0	0	0
Jun-24	751,000	36,320	0	36,320	0
Jul-24	609,000	287,904	40,900	158,129	88,875
Aug-24	534,000	437,438	160,147	154,928	122,363
Sep-24	736,000	606,439	210,900	212,931	182,608
Oct-24	1,131,000	891,062	305,664	305,170	280,228
Nov-24	1,281,000	1,295,840	432,081	436,598	427,161
Dec-24	1,263,000	1,438,878	481,285	479,933	477,660
Jan-25	1,433,000	1,599,858	537,089	534,083	528,686
Feb-25	1,213,000	997,448	335,547	336,861	325,040
Production 2025 (ytd) (kWh)	2,646,000	2,597,306	872,636	870,944	853,726
Total Production (LTM) (kWh)	12,669,000	7,591,244	2,503,613	2,654,953	2,432,678
Capacity Factor (LTM)	19.26%				

B. Site Energy Production GraphFebruary-2025



Monthly ReportFebruary-2025

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2025	4.5 Year Preventive Maintenance	~8	L1
April-2025	4.5 Year Preventive Maintenance	~8	L2
April-2025	4.5 Year Preventive Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/6/2025	Weather Shutdown	Unplanned	6.65	L1,L2,L3
2/8/2025-2/9/2025	Weather Shutdown	Unplanned	23.01	L1
2/8/2025-2/9/2025	Weather Shutdown	Unplanned	23.38	L2
2/8/2025-2/9/2025	Weather Shutdown	Unplanned	23.48	L3
2/9/2025-2/10/2025	Weather Shutdown	Unplanned	11.33	L1
2/9/2025-2/10/2025	Weather Shutdown	Unplanned	11.33	L2
2/9/2025-2/10/2025	Weather Shutdown	Unplanned	20.5	L3
2/12/2025-2/15/2025	Weather Shutdown	Unplanned	67.53	L1
2/12/2025-2/15/2025	Weather Shutdown	Unplanned	66.97	L2
2/12/2025-2/15/2025	Weather Shutdown	Unplanned	67.95	L3
2/19/2025	4.5 Year Preventive Maintenance	Planned	4.14	L1,L2,L3

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
L1	112.66	112.66
L2	112.47	112.47
L3	122.72	122.72
Total	347.85	347.85

G. Billed Data

Meter Reading (Date/Time)	2/26/2025 12:00 AM
Meter To Date Produced	47,993,970 kWh
Meter To Date Consumed	217,067 kWh
Last Reading Produced	46,942,252 kWh
Last Reading Consumed	213,351 kWh
Billed kWh	1,048,002 kWh
Next Meter Reading	3/27/2025 12:00 AM

H. Report Notes and Comments

¹Turbine Availability/Downtime Pending.
²As a result of previously disclosed circumstances, other than 57kWh for testing, The project had no energy production from February 2024 - May 2024..
³As a result of previously disclosed circumstances, L1, and L3 had no energy production February 2024 - June 2024.