


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	
Feb-24	917,000	0	0	0	2
Mar-24	802,000	0	0	0	2
Apr-24	951,000	231,529	116,676	114,853	
May-24	601,000	464,507	229,425	235,082	
Jun-24	425,000	469,571	236,472	233,099	
Jul-24	390,000	301,440	152,091	149,349	
Aug-24	399,000	280,180	140,866	139,314	
Sep-24	337,000	370,064	187,230	182,834	
Oct-24	637,000	572,084	289,438	282,646	
Nov-24	834,000	785,699	390,357	395,342	
Dec-24	1,015,000	893,806	444,191	449,615	
Jan-25	875,000	1,030,662	504,989	525,673	
Feb-25	917,000	541,951	268,768	273,183	
Production 2025 (ytd) (kWh)	1,792,000	1,572,613	773,757	798,856	
Total Production (LTM) (kWh)	8,183,000	5,941,493	2,960,503	2,980,990	
Capacity Factor (LTM)	22.61%				

B. Site Energy Production Graph



Monthly Report
February-2025

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
March-2025	9 Year Preventive Maintenance	~15	W1
March-2025	9 Year Preventive Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/3/2025	9 Year Preventive Maintenance	Planned	0.81	W1
2/3/2025	9 Year Preventive Maintenance	Planned	1.02	W2
2/6/2025	Weather Shutdown	Unplanned	5.61	W1,W2
2/7/2025	9 Year Preventive Maintenance	Unplanned	5.43	W2
2/8/2025-2/9/2025	Weather Shutdown	Unplanned	24.50	W1
2/8/2025-2/9/2025	Weather Shutdown	Unplanned	24.67	W2
2/11/2025	9 Year Preventive Maintenance	Planned	5.28	W1
2/12/2025	9 Year Preventive Maintenance	Planned	1.98	W1, W2
2/12/2024-2/17/2025	Weather Shutdown	Unplanned	113.72	W1
2/13/2025-2/15/2025	Weather Shutdown	Unplanned	60.86	W2
2/16/2025-2/17/2025	Weather Shutdown	Unplanned	26.78	W2
2/18/2025	Turbine Fault	Unplanned	4.61	W1
2/25/2025	9 Year Preventive Maintenance	Planned	4.9	W1

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
W1	166.89	199.48
W2	128.47	129.16
Total	295.36	328.64

G. Billed Data

Meter Reading (Date/Time)	3/1/2025 12:00 AM
Meter To Date Produced	67,349,141 kWh
Meter To Date Consumed	158,462 kWh
Last Reading Produced	66,716,112 kWh
Last Reading Consumed	156,002 kWh
Billed kWh	630,569 kWh
Next Meter Reading	3/29/2025 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending

² As a result of previously disclosed circumstances, the project had no energy production February 2024 - March 2024.