


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	V1	V2	
Feb-24	737,000	0	0	0	2
Mar-24	777,000	0	0	0	2
Apr-24	722,000	0	0	0	2
May-24	564,000	0	0	0	2
Jun-24	422,000	26,106	0	26,106	3
Jul-24	351,000	270,166	124,029	146,137	
Aug-24	303,000	261,120	136,201	124,919	
Sep-24	431,000	390,486	185,589	204,897	
Oct-24	674,000	522,777	233,362	289,415	
Nov-24	796,000	678,634	359,728	318,906	
Dec-24	820,000	821,736	388,737	432,999	
Jan-25	931,000	988,728	488,844	499,884	
Feb-25	737,000	528,117	268,790	259,327	
Production 2025 (ytd) (kWh)	1,668,000	1,516,845	757,634	759,211	
Total Production (LTM) (kWh)	7,528,000	4,487,870	2,185,280	2,302,590	
Capacity Factor (LTM)	17.08%				

B. Site Energy Production Graph

February-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2025	6 Year Maintenance	~15	V1
April-2025	6 Year Maintenance	~15	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/5/2025-2/6/2025	Weather Shutdown	Unplanned	7.66	V1,V2
2/8/2025-2/9/2025	Weather Shutdown	Unplanned	23.93	V1
2/8/2025-2/9/2025	Weather Shutdown	Unplanned	24.04	V2
2/12/2025-2/15/2025	Weather Shutdown	Unplanned	64.24	V1
2/12/2025-2/13/2025	Weather Shutdown	Unplanned	15.09	V2
2/16/2025-2/17/2025	Weather Shutdown	Unplanned	28.06	V1
2/16/2025-2/17/2025	Weather Shutdown	Unplanned	27.22	V2
2/20/2025	6 Year Maintenance	Planned	2.66	V1
2/20/2025	6 Year Maintenance	Planned	2.69	V2
2/21/2025-2/24/2025	Turbine Fault	Unplanned	62.91	V2

F. Downtime¹

Downtime (hr)	This Month	Year To Date
V1	130.39	131.82
V2	143.59	151.75
Total	273.98	283.57

G. Billed Data

Meter Reading (Date/Time)	3/1/2025 12:00 AM
Meter To Date Produced	43,008,916 kWh
Meter To Date Consumed	124,017 kWh
Last Reading Produced	42,498,615 kWh
Last Reading Consumed	122,422 kWh
Billed kWh	508,706 kWh
Next Meter Reading	4/1/2025 12:00 AM

H. Report Notes and Comments

¹Turbine Availability/Downtime Pending.

²As a result of previously disclosed circumstances, the project had no energy production February 2024 - May 2024.

³As a result of previously disclosed circumstances, V1 had no energy production February 2024 - June 2024.