


A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3	
Feb-24	1,133,000	0	0	0	0	2
Mar-24	1,312,000	0	0	0	0	2
Apr-24	1,272,000	165,611	81,100	0	84,511	3
May-24	974,000	443,966	224,384	0	219,582	3
Jun-24	714,000	457,519	234,750	0	222,769	3
Jul-24	566,000	306,010	138,508	26,329	141,173	
Aug-24	514,000	412,680	141,710	134,341	136,629	
Sep-24	716,000	531,587	183,534	168,417	179,636	
Oct-24	1,051,000	881,013	307,605	290,645	282,763	
Nov-24	1,224,000	1,122,327	391,525	369,519	361,283	
Dec-24	1,217,000	1,260,023	446,812	416,052	397,159	
Jan-25	1,343,000	1,398,943	512,624	450,432	435,887	
Feb-25	1,133,000	710,891	253,926	229,140	227,825	4
Production 2025 (ytd) (kWh)	2,476,000	2,109,834	766,550	679,572	663,712	
Total Production (LTM) (kWh)	12,036,000	7,690,570	2,916,478	2,084,875	2,689,217	
Capacity Factor (LTM)	19.51%					

B. Site Energy Production Graph

February-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2025	6 Year Preventive Maintenance	~15	WG 1
May-2025	6 Year Preventive Maintenance	~15	WG 2
May-2025	6 Year Preventive Maintenance	~15	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/5/2025-2/6/2025	Weather Shutdown	Unplanned	13.44	WG1, WG2, WG3
2/8/2025-2/10/2025	Weather Shutdown	Unplanned	45.04	W1
2/8/2025-2/10/2025	Weather Shutdown	Unplanned	44.82	W2
2/8/2025-2/11/2025	Weather Shutdown	Unplanned	62.71	W3
2/12/2025-2/15/2025	Weather Shutdown	Unplanned	68.45	W1
2/12/2025-2/15/2025	Weather Shutdown	Unplanned	67.78	W2
2/12/2025-2/15/2025	Weather Shutdown	Unplanned	68.31	W3
2/16/2025-2/17/2025	Weather Shutdown	Unplanned	29.98	W1
2/16/2025-2/17/2025	Weather Shutdown	Unplanned	29.93	W2
2/16/2025-2/17/2025	Weather Shutdown	Unplanned	30.07	W3

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
WG1	157.29	158.06
WG2	155.97	159.37
WG3	174.53	176.30
`	487.79	493.73

G. Billed Data

Meter Reading (Date/Time)	3/1/2025 12:00 AM
Meter To Date Produced	64,244,280 kWh
Meter To Date Consumed	273,768 kWh
Last Reading Produced	63,374,063 kWh
Last Reading Consumed	269,276 kWh
Billed kWh	865,725 kWh
Next Meter Reading	3/29/2025 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project had no energy production February 2024 - March 2024.

³ As a result of previously disclosed circumstances, WG 2 had no energy production February 2024 - June 2024.

⁴ W2 was derated to 250 KW for .62hrs on Feb 13 for testing