


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Mar-24	1,339,000	0	0	0	0
Apr-24	1,327,000	57	0	0	57
May-24	1,052,000	0	0	0	0
Jun-24	751,000	36,320	0	36,320	0
Jul-24	609,000	287,904	40,900	158,129	88,875
Aug-24	534,000	437,438	160,147	154,928	122,363
Sep-24	736,000	606,439	210,900	212,931	182,608
Oct-24	1,131,000	891,062	305,664	305,170	280,228
Nov-24	1,281,000	1,295,840	432,081	436,598	427,161
Dec-24	1,263,000	1,438,878	481,285	479,933	477,660
Jan-25	1,433,000	1,599,858	537,089	534,083	528,686
Feb-25	1,213,000	997,448	335,547	336,861	325,040
Mar-25	1,339,000	1,720,745	567,488	574,782	578,475
Production 2025 (ytd) (kWh)	3,985,000	4,318,051	1,440,124	1,445,726	1,432,201
Total Production (LTM) (kWh)	12,669,000	9,311,989	3,071,101	3,229,735	3,011,153
Capacity Factor (LTM)	23.62%				

B. Site Energy Production Graph

March-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2025	5 Year Preventive Maintenance	~15	L1
September-2025	5 Year Preventive Maintenance	~15	L2
September-2025	5 Year Preventive Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/25/2025	4.5 Year Preventive Maintenance	Planned	5.58	L1
3/25/2025	4.5 Year Preventive Maintenance	Planned	5.43	L2
3/26/2025	4.5 Year Preventive Maintenance	Planned	4.61	L3

F. Turbine Downtime<sup>1</sup>

Downtime (hr)	This Month	Year To Date
L1	10.70	123.36
L2	10.57	123.04
L3	9.94	132.66
Total	31.21	379.06

G. Billed Data

Meter Reading (Date/Time)	3/27/2025 12:00 AM
Meter To Date Produced	49,565,040 kWh
Meter To Date Consumed	218,743 kWh
Last Reading Produced	47,993,970 kWh
Last Reading Consumed	217,067 kWh
Billed kWh	1,569,394 kWh
Next Meter Reading	4/26/2025 12:00 AM

H. Report Notes and Comments

<sup>1</sup>Turbine Availability/Downtime Pending.

<sup>2</sup>As a result of previously disclosed circumstances, other than 57kWh for testing, The project had no energy production from February 2024 - May 2024..

<sup>3</sup>As a result of previously disclosed circumstances, L1, and L3 had no energy production February 2024 - June 2024.