


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG 1	WTG 2	WTG 3
Apr-24	1,438,497	1,440,355	491,796	461,645	486,914
May-24	980,450	836,173	284,799	275,439	275,935
Jun-24	649,158	897,472	318,609	299,454	279,409
Jul-24	618,687	494,646	168,488	159,103	167,055
Aug-24	559,508	495,719	172,033	156,575	167,111
Sep-24	603,085	666,318	219,662	225,740	220,916
Oct-24	967,926	968,509	327,746	315,257	325,506
Nov-24	1,362,692	1,392,792	449,512	465,936	477,344
Dec-24	1,254,397	1,505,421	506,487	488,779	510,155
Jan-25	1,290,968	1,781,496	600,395	573,604	607,497
Feb-25	1,170,349	1,122,014	379,422	360,728	381,864
Mar-25	1,227,217	1,980,804	656,419	657,823	666,562
Apr-25	1,438,497	1,381,940	460,087	466,384	455,469
Production 2025 (ytd) (kWh)	5,127,031	6,266,254	2,096,323	2,058,539	2,111,392
Total Production (LTM) (kWh)	12,122,935	13,523,304	4,543,659	4,444,822	4,534,823
Capacity Factor (LTM)	34.31%				

B. Site Energy Production Graph

April-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2025	13 Year Maintenance	~15	WTG 1
October-2025	13 Year Maintenance	~15	WTG 2
October-2025	13 Year Maintenance	~15	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/12/2025-4/13/2025	Turbine Fault	Unplanned	34.30	WTG 3
4/16/2025	12.5 Year Maintenance	Planned	4.04	WTG 1
4/16/2025	12.5 Year Maintenance	Planned	4.32	WTG 3
4/17/2025	12.5 Year Maintenance	Planned	4.11	WTG 2
4/22/205	Turbine Inspection	Unplanned	5.87	WTG 1
4/23/2025-4/24/2025	Turbine Fault	Unplanned	22.67	WTG 3

F. Turbine Downtime ¹

Downtime (hr)	This Month	Year To Date
WTG 1	12.02	42.26
WTG 2	4.11	22.30
WTG 3	61.42	79.59
Total	77.55	144.15

G. Wind Speed & Capacity Factor ²

Wind Speed (mph)	This Month	2024 Annual
WTG 1	4.94	4.94
WTG 2	4.90	4.90
WTG 3	4.97	4.97
Estimated	16.62	13.39

Capacity Factor (%)	This Month	2024 Annual
WTG 1	42.60%	42.25%
WTG 2	43.18%	41.45%
WTG 3	42.17%	40.09%
Low Estimate	42.22%	28.72%

H. Report Notes and Comments

¹ Turbine Downtime/Availability Pending

²Wind Speed Pending