


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Apr-24	1,447,248	1,470,775	495,877	478,795	496,103
May-24	1,010,966	862,575	288,229	287,713	286,633
Jun-24	668,411	942,158	314,570	308,308	319,280
Jul-24	638,097	496,566	168,933	163,396	164,237
Aug-24	577,992	501,947	169,754	169,011	163,182
Sep-24	631,697	690,869	235,117	228,797	226,955
Oct-24	1,003,602	984,144	333,941	322,754	327,449
Nov-24	1,395,914	1,322,209	421,383	445,603	455,223
Dec-24	1,278,858	1,544,430	507,770	520,943	515,717
Jan-25	1,332,437	1,790,239	597,099	595,949	597,191
Feb-25	1,157,019	1,139,979	379,791	376,195	383,993
Mar-25	1,242,761	1,776,340	602,009	565,146	609,185
Apr-25	1,447,248	1,364,430	455,746	443,445	465,239
Production 2025 (ytd) (kWh)	5,179,464	6,070,988	2,034,645	1,980,735	2,055,608
Total Production (LTM) (kWh)	12,385,000	13,415,886	4,474,342	4,427,260	4,514,284
Capacity Factor (LTM)	34.03%				

B. Site Energy Production Graph

April-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2025	12.5 Year Maintenance	~8	WTG A
May-2025	12.5 Year Maintenance	~8	WTG B
May-2025	12.5 Year Maintenance	~8	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/19/2025	Customer Shutdown	Unplanned	4.36	WTG A

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
WTG A	4.76	8.72
WTG B	3.85	7.79
WTG C	5.31	9.38
Total	13.92	25.89

G. Wind Speed & Capacity Factor³

Wind Speed (mph)	This Month	2025 Annual
WTG A	13.90	14.56
WTG B	13.68	14.18
WTG C	14.67	15.24
Estimated	16.62	13.39

Capacity Factor (%)	This Month	2025 Annual
WTG A	42.20%	47.10%
WTG B	41.06%	31.85%
WTG C	43.08%	47.58%
Low Estimate	42.22%	28.72%

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² 10/20-2024 - 11/12/2024 WTG A production calculated from 10 min data, due to a turbine issue
2/20/2025 - 4/30/2025 WTG B production calculated from 10 min data, due to a turbine issue

³ Wind Speed Pending