


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Apr-24	499,000	113,878
May-24	318,000	259,723
Jun-24	222,000	260,126
Jul-24	201,000	113,237 ²
Aug-24	211,000	0 ²
Sep-24	182,000	0 ²
Oct-24	341,000	0 ²
Nov-24	445,000	279,948 ²
Dec-24	537,000	475,185
Jan-25	455,000	522,801
Feb-25	478,000	267,129
Mar-25	422,000	603,999
Apr-25	499,000	374,272
Production 2025 (ytd) (kWh)	1,854,000	1,768,201
Total Production (LTM) (kWh)	4,311,000	3,156,420
Capacity Factor (LTM)	24.02%	

B. Site Energy Production Graph

April-2025



Monthly Report
April-2025

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2025	7 Year Preventive Maintenance	~15	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/2/2025	Weather Shutdown	Unplanned	5.45	W1
4/19/2025-4/20/2025	Plant Shutdown	Unplanned	26.33	W1

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
W1	35.48	239.33

G. Billed Data

Meter Reading (Date/Time)	5/1/2025 12:00 AM
Meter To Date Produced	26,919,727 kWh
Meter To Date Consumed	145,361 kWh
Last Reading Produced	26,551,082 kWh
Last Reading Consumed	144,159 kWh
Billed kWh	367,443 kWh
Next Meter Reading	6/1/2025 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

³ Turbine down due to utility substation catastrophic event 7/20/2024-11/9/2024.