



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
May-24	311,000	176,362
Jun-24	228,000	182,891
Jul-24	179,000	130,160
Aug-24	157,000	115,765
Sep-24	224,000	147,046
Oct-24	338,000	226,873
Nov-24	402,000	312,105
Dec-24	403,000	344,484
Jan-25	460,000	442,965
Feb-25	372,000	254,448
Mar-25	417,000	437,434
Apr-25	399,000	341,094
May-25	311,000	252,513
Production 2025 (ytd) (kWh)	1,959,000	1,728,454
Total Production (LTM) (kWh)	3,890,000	3,187,778
Capacity Factor (LTM)	24.26%	

B. Site Energy Production Graph

May-2025



Monthly Report

May-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2025	9 Year Preventive Maintenance	~15	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
5/5/2025	Grid Fault	Unplanned	4.00	H1

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
H1	16.58	244.99

G. Billed Data

Meter Reading (Date/Time)	5/28/2025 12:00 AM
Meter To Date Produced	29,314,072 kWh
Meter To Date Consumed	111,255 kWh
Last Reading Produced	29,037,167 kWh
Last Reading Consumed	110,628 kWh
Billed kWh	276,278 kWh
Next Meter Reading	6/26/2025 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.