


A. Site Energy Production Summary

|                              | Energy Production (kWh) |                   |            |           |           |
|------------------------------|-------------------------|-------------------|------------|-----------|-----------|
|                              | Site                    |                   | By Turbine |           |           |
|                              | Expected Production     | Actual Production | WTG A      | WTG B     | WTG C     |
| May-24                       | 1,010,966               | 862,575           | 288,229    | 287,713   | 286,633   |
| Jun-24                       | 668,411                 | 942,158           | 314,570    | 308,308   | 319,280   |
| Jul-24                       | 638,097                 | 496,566           | 168,933    | 163,396   | 164,237   |
| Aug-24                       | 577,992                 | 501,947           | 169,754    | 169,011   | 163,182   |
| Sep-24                       | 631,697                 | 690,869           | 235,117    | 228,797   | 226,955   |
| Oct-24                       | 1,003,602               | 984,144           | 333,941    | 322,754   | 327,449   |
| Nov-24                       | 1,395,914               | 1,322,209         | 421,383    | 445,603   | 455,223   |
| Dec-24                       | 1,278,858               | 1,544,430         | 507,770    | 520,943   | 515,717   |
| Jan-25                       | 1,332,437               | 1,790,239         | 597,099    | 595,949   | 597,191   |
| Feb-25                       | 1,157,019               | 1,139,979         | 379,791    | 376,195   | 383,993   |
| Mar-25                       | 1,242,761               | 1,776,340         | 602,009    | 565,146   | 609,185   |
| Apr-25                       | 1,447,248               | 1,364,430         | 455,746    | 443,445   | 465,239   |
| May-25                       | 1,010,966               | 1,056,568         | 359,208    | 333,884   | 363,476   |
| Production 2025 (ytd) (kWh)  | 6,190,430               | 7,127,556         | 2,393,853  | 2,314,619 | 2,419,084 |
| Total Production (LTM) (kWh) | 12,385,000              | 13,609,879        | 4,545,321  | 4,473,431 | 4,591,127 |
| Capacity Factor (LTM)        | 34.53%                  |                   |            |           |           |

B. Site Energy Production Graph



C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| Near Miss(es)          | 0          | 0                  |

D. Planned Maintenance Events

| Date          | Event               | Duration (hr) | Turbine |
|---------------|---------------------|---------------|---------|
| November-2025 | 13 Year Maintenance | ~15           | WTG A   |
| November-2025 | 13 Year Maintenance | ~15           | WTG B   |
| November-2025 | 13 Year Maintenance | ~15           | WTG C   |

E. Actual Maintenance Events

| Date      | Event                 | Planned/Unplanned | Duration (hrs) | Turbine |
|-----------|-----------------------|-------------------|----------------|---------|
| 5/28/2025 | 12.5 Year Maintenance | Planned           | 4.39           | WTG A   |
| 5/29/2025 | 12.5 Year Maintenance | Planned           | 1.53           | WTG A   |
| 5/29/2025 | 12.5 Year Maintenance | Planned           | 4.81           | WTG C   |
| 5/29/2025 | 12.5 Year Maintenance | Planned           | 5.94           | WTG B   |

F. Turbine Downtime<sup>1</sup>

| Downtime (hr) | This Month | Year To Date |
|---------------|------------|--------------|
| WTG A         | 5.98       | 14.70        |
| WTG B         | 6.01       | 13.80        |
| WTG C         | 4.88       | 14.26        |
| Total         | 16.87      | 42.76        |

G. Wind Speed & Capacity Factor<sup>3</sup>

| Wind Speed (mph) | This Month | 2025 Annual |
|------------------|------------|-------------|
| WTG A            | 11.88      | 14.01       |
| WTG B            | 11.49      | 13.63       |
| WTG C            | 12.58      | 14.69       |
| Estimated        | 13.57      | 13.39       |

| Capacity Factor (%) | This Month | 2025 Annual |
|---------------------|------------|-------------|
| WTG A               | 32.19%     | 44.04%      |
| WTG B               | 29.92%     | 31.85%      |
| WTG C               | 32.57%     | 44.50%      |
| Low Estimate        | 28.39%     | 28.72%      |

H. Report Notes and Comments

<sup>1</sup> Turbine Availability/Downtime Pending.

<sup>2</sup> 10/20-2024 - 11/12/2024 WTG A production calculated from 10 min data, due to a turbine issue  
2/20/2025 - 5/31/2025 WTG B production calculated from 10 min data, due to a turbine issue

<sup>3</sup> Wind Speed Pending