

Holcim - Paulding Wind Project


LafargeHolcim Holcim - Paulding Wind Project, Paulding, Ohio

A. Site Energy Production Summary

		Energy Production (kWh)					
		Site			By Turbine		
		P50 (Expected	Actual	L1	L2	L3	
		Prodution)	Production	LI	LL	LO	
	May-24	1,052,000	0	0	0	0	
	Jun-24	751,000	36,320	0	36,320	0	
	Jul-24	609,000	287,904	40,900	158,129	88,875	
	Aug-24	534,000	437,438	160,147	154,928	122,363	
	Sep-24	736,000	606,439	210,900	212,931	182,608	
	Oct-24	1,131,000	891,062	305,664	305,170	280,228	
	Nov-24	1,281,000	1,295,840	432,081	436,598	427,161	
	Dec-24	1,263,000	1,438,878	481,285	479,933	477,660	
	Jan-25	1,433,000	1,599,858	537,089	534,083	528,686	
	Feb-25	1,213,000	997,448	335,547	336,861	325,040	
	Mar-25	1,339,000	1,720,745	567,488	574,782	578,475	
	Apr-25	1,327,000	1,163,622	345,083	408,595	409,944	
	May-25	1,052,000	907,488	305,239	310,309	291,940	
Production 2025 (ytd) (kWh)		6,364,000	6,389,161	2,090,446	2,164,630	2,134,085	
Total Production (LTM) (kWh)		12,669,000	11,383,042	3,721,423	3,948,639	3,712,980	
Capacity Factor (LTM)		28.8	88%				

B. Site Energy Production Graph





Monthly Report May-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

		Duration	
Date	Event	(hr)	Turbine
July-2025	5 Year Preventive Maintenance	~15	L1
July-2025	5 Year Preventive Maintenance	~15	L2
July-2025	5 Year Preventive Maintenance	~15	L3

E. Actual Maintenance Events

		Planned/	Duration	
Date	Event	Unplanned	(hrs)	Turbine

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
L1	3.86	194.47
L2	3.86	127.70
L3	8.87	142.67
Total	16.59	464.84

G. Billed Data

Meter Reading (Date/Time)	5/28/2025 12:00 AM
Meter To Date Produced	51,818,857 kWh
Meter To Date Consumed	223,783 kWh
Last Reading Produced	50,803,353 kWh
Last Reading Consumed	221,149 kWh
Billed kWh	1,012,870 kWh
Next Meter Reading	6/26/2025 12:00 AM

H. Report Notes and Comments

¹Turbine Availability/Downtime Pending.

²As a result of previously disclosed circumstances, other than 57kWh for testing, The project had no energy production from February 2024 - May 2024...

³As a result of previously disclosed circumstances, L1, and L3 had no energy production February 2024 - June 2024.