


A. Site Energy Production Summary

		Energy Production (kWh)				
		Site		By Turbine		
		P50 (Expected Production)	Actual Production	V1	V2	
	May-24	564,000	0	0	0	2
	Jun-24	422,000	26,106	0	26,106	3
	Jul-24	351,000	270,166	124,029	146,137	
	Aug-24	303,000	261,120	136,201	124,919	
	Sep-24	431,000	390,486	185,589	204,897	
	Oct-24	674,000	522,777	233,362	289,415	
	Nov-24	796,000	678,634	359,728	318,906	
	Dec-24	820,000	821,736	388,737	432,999	
	Jan-25	931,000	988,728	488,844	499,884	
	Feb-25	737,000	528,117	268,790	259,327	
	Mar-25	777,000	1,057,937	508,748	549,189	
	Apr-25	722,000	638,257	280,584	357,673	
	May-25	564,000	578,589	290,047	288,542	
Production 2025 (ytd) (kWh)		3,731,000	3,791,628	1,837,013	1,954,615	
Total Production (LTM) (kWh)		7,528,000	6,762,653	3,264,659	3,497,994	
Capacity Factor (LTM)		25.73%				

B. Site Energy Production Graph

May-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2025	6.5 Year Maintenance	~15	V1
September-2025	6.5 Year Maintenance	~15	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Downtime¹

Downtime (hr)	This Month	Year To Date
V1	4.12	297.10
V2	4.28	163.26
Total	8.40	460.36

G. Billed Data

Meter Reading (Date/Time)	6/1/2025 12:00 AM
Meter To Date Produced	45,215,301 kWh
Meter To Date Consumed	127,099 kWh
Last Reading Produced	44,655,363 kWh
Last Reading Consumed	125,987 kWh
Billed kWh	558,826 kWh
Next Meter Reading	7/1/2025 12:00 AM

H. Report Notes and Comments

¹Turbine Availability/Downtime Pending.

²As a result of previously disclosed circumstances, the project had no energy production February 2024 - May 2024.

³As a result of previously disclosed circumstances, V1 had no energy production February 2024 - June 2024.