


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG 1	WTG 2	WTG 3
Jun-24	649,158	897,472	318,609	299,454	279,409
Jul-24	618,687	494,646	168,488	159,103	167,055
Aug-24	559,508	495,719	172,033	156,575	167,111
Sep-24	603,085	666,318	219,662	225,740	220,916
Oct-24	967,926	968,509	327,746	315,257	325,506
Nov-24	1,362,692	1,392,792	449,512	465,936	477,344
Dec-24	1,254,397	1,505,421	506,487	488,779	510,155
Jan-25	1,290,968	1,781,496	600,395	573,604	607,497
Feb-25	1,170,349	1,122,014	379,422	360,728	381,864
Mar-25	1,227,217	1,980,804	656,419	657,823	666,562
Apr-25	1,438,497	1,381,940	460,087	466,384	455,469
May-25	980,450	976,885	328,058	325,817	323,010
Jun-25	649,158	665,664	233,741	206,179	225,744
Production 2025 (ytd) (kWh)	6,756,639	7,908,803	2,658,122	2,590,535	2,660,146
Total Production (LTM) (kWh)	12,122,935	13,432,208	4,502,050	4,401,925	4,528,233
Capacity Factor (LTM)	34.07%				

B. Site Energy Production Graph

June-2025



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2025	13 Year Maintenance	~15	WTG 1
October-2025	13 Year Maintenance	~15	WTG 2
October-2025	13 Year Maintenance	~15	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/4/2025-6/5/2025	Grid Fault	Unplanned	24.08	WTG 1
6/4/2025-6/5/2025	Grid Fault	Unplanned	25.78	WTG 2
6/4/2025-6/5/2025	Grid Fault	Unplanned	24.06	WTG 3
6/12/2025-6/13/2025	Grid Fault	Unplanned	11.12	WTG 1
6/12/2025-6/13/2025	Grid Fault	Unplanned	20.60	WTG 2
6/12/2025	Grid Fault	Unplanned	9.16	WTG 3
6/18/2025-6/20/2025	Grid Fault	Unplanned	39.06	WTG 1, WTG 2, WTG 3

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
WTG 1	77.39	137.85
WTG 2	92.52	133.02
WTG 3	76.84	177.02
Total	246.75	447.89

G. Wind Speed & Capacity Factor²

Wind Speed (mph)	This Month	2024 Annual
WTG 1	4.94	4.94
WTG 2	4.90	4.90
WTG 3	4.97	4.97
Estimated	11.44	13.39

Capacity Factor (%)	This Month	2024 Annual
WTG 1	21.64%	42.25%
WTG 2	19.09%	41.45%
WTG 3	20.90%	40.09%
Low Estimate	17.87%	28.72%

H. Report Notes and Comments

¹ Turbine Downtime Pending

² Wind Speed Pending