



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Jun-24	228,000	182,891
Jul-24	179,000	130,160
Aug-24	157,000	115,765
Sep-24	224,000	147,046
Oct-24	338,000	226,873
Nov-24	402,000	312,105
Dec-24	403,000	344,484
Jan-25	460,000	442,965
Feb-25	372,000	254,448
Mar-25	417,000	437,434
Apr-25	399,000	341,094
May-25	311,000	252,513
Jun-25	228,000	145,374
Production 2025 (ytd) (kWh)	2,187,000	1,873,828
Total Production (LTM) (kWh)	3,890,000	3,150,261
Capacity Factor (LTM)	23.97%	

B. Site Energy Production Graph

June-2025



Monthly Report

June-2025



ONE POWER COMPANY

AN INDUSTRIAL POWER COMPANY

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2025	9 Year Preventive Maintenance	~15	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/1/2025-6/3/2025	Turbine Fault	Unplanned	47.59	H1

F. Turbine Downtime and Uptime¹

Downtime (hr)	This Month	Year To Date
H1	51.01	296.00
Uptime (hrs)	Life Time	
H1	81936.00	

G. Billed Data

Meter Reading (Date/Time)	6/26/2025 12:00 AM
Meter To Date Produced	29,460,862 kWh
Meter To Date Consumed	112,305 kWh
Last Reading Produced	29,314,072 kWh
Last Reading Consumed	111,255 kWh
Billed kWh	145,740 kWh
Next Meter Reading	7/26/2025 12:00 AM

H. Report Notes and Comments

¹ Turbine Downtime and Uptime Pending.