


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Jun-24	425,000	469,571	236,472	233,099
Jul-24	390,000	301,440	152,091	149,349
Aug-24	399,000	280,180	140,866	139,314
Sep-24	337,000	370,064	187,230	182,834
Oct-24	637,000	572,084	289,438	282,646
Nov-24	834,000	785,699	390,357	395,342
Dec-24	1,015,000	893,806	444,191	449,615
Jan-25	875,000	1,030,662	504,989	525,673
Feb-25	917,000	541,951	268,768	273,183
Mar-25	802,000	1,129,812	567,643	562,169
Apr-25	951,000	699,169	361,078	338,091
May-25	601,000	577,922	289,767	288,155
Jun-25	425,000	435,580	213,984	221,596
Production 2025 (ytd) (kWh)	4,571,000	4,415,096	2,206,229	2,208,867
Total Production (LTM) (kWh)	8,183,000	7,618,369	3,810,402	3,807,967
Capacity Factor (LTM)	28.99%			

B. Site Energy Production Graph

June-2025



Monthly Report

June-2025

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2025	9.5 Year Preventive Maintenance	~15	W1
September-2025	9.5 Year Preventive Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/2/2025-6/3/2025	Customer Shutdown	Unplanned	28.99	W1
6/4/2025	Customer Shutdown	Unplanned	4.71	W2
6/12/2025	Customer Shutdown	Unplanned	10	W2

F. Turbine Downtime and Uptime¹

Downtime (hr)	This Month	Year To Date
W1	38.53	263.42
W2	19.30	247.32
Total	57.83	510.74

Uptime (hrs)	Life Time
W1, W2	82608.00

G. Billed Data

Meter Reading (Date/Time)	6/29/2025 12:00 AM
Meter To Date Produced	70,143,298 kWh
Meter To Date Consumed	161,726 kWh
Last Reading Produced	69,681,465 kWh
Last Reading Consumed	160,802 kWh
Billed kWh	460,909 kWh
Next Meter Reading	7/29/2025 12:00 AM

H. Report Notes and Comments

¹ Turbine Downtime and Uptime Pending