


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Jun-24	222,000	260,126
Jul-24	201,000	113,237
Aug-24	211,000	0
Sep-24	182,000	0
Oct-24	341,000	0
Nov-24	445,000	279,948
Dec-24	537,000	475,185
Jan-25	455,000	522,801
Feb-25	478,000	267,129
Mar-25	422,000	603,999
Apr-25	499,000	374,272
May-25	318,000	304,947
Jun-25	222,000	243,353
Production 2025 (ytd) (kWh)	2,394,000	2,316,501
Total Production (LTM) (kWh)	4,311,000	3,184,871
Capacity Factor (LTM)	24.24%	

B. Site Energy Production Graph

June-2025



Monthly Report
June-2025

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2025	7 Year Preventive Maintenance	~15	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Downtime and Uptime ¹

Downtime (hr)	This Month	Year To Date
W1	7.46	250.41
Uptime (hrs)	Life Time	
W1	64368.00	

G. Billed Data

Meter Reading (Date/Time)	7/1/2025 12:00 AM
Meter To Date Produced	27,458,872 kWh
Meter To Date Consumed	148,176 kWh
Last Reading Produced	27,219,740 kWh
Last Reading Consumed	146,553 kWh
Billed kWh	237,509 kWh
Next Meter Reading	8/1/2025 12:00 AM

H. Report Notes and Comments

¹ Turbine Downtime and Uptime Pending.

³ Turbine down due to utility substation catastrophic event 7/20/2024-11/9/2024.